

2022 PFAS6 RESULTS SUMMARY TABLES

PFAS6 Results for Forge Village Water Treatment Plant				
Quarterly Compliance Period	Monitoring Period	PFAS6 Result (ng/L)	*Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 1, 2022	January	7.10	4.77	20
	February	3.80		
	March	3.40		
Quarter 2, 2022	April	3.60	4.70	20
	May	3.90		
	June	6.60		
Quarter 3, 2022	July	6.90	4.70	20
	August	3.80		
	September	3.40		
Quarter 4, 2022	October	3.80	3.87	20
	November	3.70		
	December	4.10		

PFAS6 Results for Nutting Road Water Treatment Plant				
Quarterly Compliance Period	Monitoring Period	PFAS6 Result (ng/L)	*Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 1, 2022	January	19.1	17.3	20
	February	15.4		
	March	17.4		
Quarter 2, 2022	April	17.6	16.8	20
	May	15.8		
	June	17.0		
Quarter 3, 2022	July	16.3	16.0	20
	August	15.3		
	September	16.3		
Quarter 4, 2022	October	15.3	14.93	20
	November	14.6		
	December	14.9		

* Quarterly averages are calculated by adding the three-monthly sample results from within the quarter and dividing by three. If any sample result would cause the quarterly average to exceed the MCL, the PFAS6 MCL has been violated.

All results are in ng/L (ppt).

